EFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası KOCAELİ/TÜRKİYE
www.efectis.com

TEST CERTIFICATE

Certificate No: EEA – 1700 – 0051 – REV2

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 06.06.2017 in accordance with EN 81-58:2003 standard for the product as described below:

" LK 01 " LIFT LANDING DOOR

Double Leaf Telescopic

FIRE RESISTANCE CLASSIFICATION
E 120, EW 60

Placed on the Market by

DELTATEK ASANSÖR SAN. VE TİC. LTD. ŞTİ.
İmes San. Sit. C Blok 308. Sok. No:6 Y.Dudullu, Ümraniye, İSTANBUL, TURKEY
And Produced in the Factory

DELTATEK ASANSÖR SAN. VE TİC. LTD. ŞTİ.
İmes San. Sit. C Blok 308. Sok. No:6 Y.Dudullu, Ümraniye, İSTANBUL, TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **RFTR17087**.

This certificate is initially valid until **19th September 2021** providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
18.09.2020